



PIPE	D	W	B
PVC	0"-12"	12" MIN. 18" MAX.	4"
A-C, V.C.P.	0"-12"	6" MIN. 12" MAX.	4"
DIP	0"-24"	6" MIN. 12" MAX.	4"
A-C, CONC.	0"-24"	6" MIN. 12" MAX.	4"
CONC. DIP	24" +	6" MIN. 12" MAX.	4"

NOTES:

1. MINIMUM TRENCH WIDTH (SEE TABLE).
2. RECESS TRENCH TO RELIEVE THE BELL OF ALL LOAD.
3. 2NS BACKFILL TO DEPTH OF ONE FOOT ABOVE PIPE. TAMPED LAYERS NOT TO EXCEED 6" IN DEPTH.
4. ALL PIPE TO BE PLACED AND JOINTED IN A DRY TRENCH AND LAID ACCURATELY TO LINE AND GRADE WITH BELLS UPHILL.
5. ALL CONCRETE ENCASEMENT AND CRADLING TO BE CLASS "A" CONCRETE.

BEDDING

S: \CIVIL\DETAILS\PITTSFIELD\
BEDDING
12-05